## 消防處 牌照及審批總區

香港九龍尖沙咀東部嚴莊道1號5櫻 消防總部大厦



## FIRE SERVICES DEPARTMENT LICENSING & CERTIFICATION COMMAND

FIRE SERVICES HEADQUARTERS BUILDING. 5/F, No. 1 Hong Chong Road, Tsim Sha Tsui East, Kowloon, Hong Kong

本處構號 Our Ref.: (80) in FP(LC) 321/12 Pt. 9

來函檔號 Your Ref.:

圖文傳真 Fax: 852-2723 2197 指 Tel. No. 852-2733 7592

爾子鄉件 E-mail: lepotic2@hkfsd.gov.hk

20 October 2008

C.M.(ASIA) Fire Equipment Co.

Rm.1206, 12/F,

Hang Pont Commerical Building, 31 Tonkin Street, Cheung Sha Wan, Kln.

(Attn.: Mr. CHENG) Fax: 8147 2182

Dear Mr. CHENG,

# Self-contained Luminaires Emergency Lighting Systems

Reference is made to your letter of 9 October 2008 and the relevant test report for the following model of self-contained luminaires emergency lighting systems.

### Brand Name

No. 1

#### Model

A850-2-4

I would like to inform you that in accordance with the FSD Circular Letter No. 1/2007 Guidelines on New Arrangement on Product Approval of Fire Service Installations and Equipment, application to this Department for prior approval / acceptance of emergency lighting systems (including self-contained luminaires emergency lighting systems) is not required.

Nevertheless, according to your submitted test reports, the captioned self-contained luminaires emergency lighting systems are deemed to comply with the specifications of Clauses 3 to 8 of "Requirements for Self-contained Luminaires Emergency Lighting Systems"  $[PPA/104(A)(4^{th} Revision)].$ 

Should you require further information or clarification regarding the above, please feel free to contact Mr. SZE Man-yuk at 2733 7875 or the undersigned direct.

Yours faithfully

(CHAN Suen-to) for Director of Fire Services

Ref. Number and date should be quoted in reference to this letter 凡提及本信時請引巡編號及日期