

消防處
牌照及審批總區

香港九龍尖沙咀東部康莊道1號5樓
消防總部大廈



FIRE SERVICES DEPARTMENT
LICENSING & CERTIFICATION COMMAND
FIRE SERVICES HEADQUARTERS BUILDING,
5/F, No. 1 Hong Chong Road,
Tsim Sha Tsui East, Kowloon,
Hong Kong

本處檔號 Our Ref.: (215) in FP(LC) 321/12 Pt.12

來函檔號 Your Ref.:

圖文傳真 Fax: 852-2723 2197

電話 Tel. No. 852-2733 7596

電子郵件 E-mail: lc2@hksfd.gov.hk

13 May 2010

C.M. (ASIA) Fire Equipment Co.
Rm 10, 13/F, Siu Wai Ind Bldg.,
29-33 Wing Hong Street, Lai Chi Kok,
Kowloon
(Attn.: Mr. CHENG)
Fax : 81472182

Dear Mr. CHENG,

Self-contained Luminaires Emergency Lighting System(s)

Reference is made to your letter of 18 March 2010 and the relevant test report(s) for the following model of self-contained luminaires emergency lighting system(s).

Item	Brand Name	Model
(1)	NO. 1	CA-850-C3W
(2)	NO. 1	CA-850-C3Y

I would like to inform you that in accordance with the FSD Circular Letter No. 1/2007 Guidelines on New Arrangement on Product Approval of Fire Service Installations and Equipment, application to this Department for prior approval / acceptance of emergency lighting systems (including self-contained luminaires emergency lighting systems) is not required.

Nevertheless, according to your submitted test report(s), the captioned self-contained luminaires emergency lighting system(s) is/are deemed to comply with the specifications of Clauses 3 to 8 of "Requirements for Self-contained Luminaires Emergency Lighting Systems" [PPA/104(A)(4th Revision)].

Should you require further information or clarification regarding the above, please feel free to contact Mr. WONG Yuk-fung at 2733 7660 or the undersigned direct.

Yours faithfully,


(CHAN Suen-to)
for Director of Fire Services