



Rep No.20120846B

TEST REPORT


Client Name Automation Technology (HK) Limited

Name of product FIRE STROBE LIGHT

Manufacturer Automation Technology (HK) Limited

Trade mark & model ATM AGB01

Test sort Entrusted Test



CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.

Address: Electronic Testing Building, Shahe Road, Xili, Nanshan District, Shenzhen, China

P.C.: 518055

TEL: 0755-26626067

FAX: 0755-26627238

Internet: <http://www.ccic-set.com>

E-Mail: james@ccic-set.com



Rep No. 20120846B

CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.

Test Report

Name of sample	PIRE STROBE LIGHT		Trade mark	ATM	
Manufacturer	Automation Technology (HK) Limited		Model/Type	AGB01	
Client	Automation Technology (HK) Limited		Sampling method	Sent by Client	
Sampler	--		Amount of samples	--	
Sampling place	--		Quantity of samples	1 Pc	
Production date	--	Sampling date	Application data		2012.08.20
Test date	2012.08.20-2012.08.27		Environment condition	23°C 53%RH	

Sample description:
 1 sample under test. No. 1#.
 The EUT's function was checked before the test. EUT functioned normally during the function check.

Test item:
 Function Test

Reference documents:
 Clause 9.7 of BS5839 Part 1: 1988
 EN 54-23:2010
 HKFSD Circular Letter 4/2001 Point 3.(ii) and 4.(i),(ii),(iv)
 User Manual

Summary:
 Function Test (Power Supply Voltage, Power Consumption, Current Consumption, Brightness, Flash frequency) was applied to the EUT according with User Manual. The EUT's performance complied with User Manual's requirements.

Test conclusion:
 The EUT's performance complied with User Manual's requirements.



Tested by [Signature] 2012 Y 8 M 27 D
 Reviewed by [Signature] 2012 Y 8 M 27 D
 Approved by [Signature] 2012 Y 8 M 27 D



Rep No. 20120846B

Test Result				
No	Test Item	Manual Requirement	Test Result	Conclusion
1	Power Supply Voltage☆	DC 18~28V	DC 18~28V	PASS
2	Power Consumption☆	Max 1.5W	0.751W	PASS
3	Current Consumption☆	Max 35mA	32.30mA	PASS
4	Brightness☆	Min 120cd/m ²	178 cd/m ²	PASS
5	Flash frequency☆	1Hz~2.5Hz	1Hz	PASS

Test Instruments

Description	Manufacturer	Model No.	Calibration Due Date	Serial No.
Digital Power Meter	YOGOGAWA	WT210	2013.06.19	A0706491
Luminance Colorimeter	TOPCON	BM-7A	2012.11.18	00480492
Stopwatch	/	PC2010	2013.04.18	206240

Note: Test instrument is valid in the period of testing.

The following is blank



Rep No. 20120846B

STATEMENT

1. This test laboratory is accredited by CNAS, Accreditation Certificate No.L1659.
2. The test report is invalid without stamp of laboratory.
3. The test report is invalid without signature of person(s) testing and authorizing.
4. The test report is invalid if erased and corrected.
5. Test results of the report is valid to the test samples if sampling by client.
6. "☆" item cannot be Accredited by CNAS.
7. The test report shall not be reproduced except in full, without written approval of the laboratory.
8. If there is any objection to report, the client should inform issuing laboratory within 15 days from the date of receiving test report.



Address: Electronic Testing Building, Shahe Road, Xili, Nanshan District, Shenzhen, China
P.C.: 518055
TEL: 0755-26626067 FAX: 0755-26627238
Internet: <http://www.ccic-sel.com> E-Mail: jamas@ccic-sel.com