

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
5/F, FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, Tsim Sha Tsui East,
Kowloon, Hong Kong.

本處檔號 OUR REF.: (4) in FP/206/1327(I)
個案編號 LIFIPS No.: 105279
來函檔號 YOUR REF.: -
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk
圖文傳真 FAX: (852) 2723 2197
電 話 TEL NO.: (852) 2733 7605

27 June 2013

Automation Technology (HK) Limited
Room 603, 6/F.,
Chevalier Commercial Centre,
8 Wang Hoi Road,
Kowloon Bay,
Kowloon,
Hong Kong

Dear Sirs,

**Application for Acceptance of
Strobe Light - ATM AGB02**

I refer to my interim reply of 5 March 2013 on the captioned subject.

Please be informed that according to the FSD Circular Letter No. 1/2007, captioned equipment is not on the list of "Fire Service Installations and Equipment Requiring FSD Approval" and therefore application for its prior acceptance by this Department is not required. Please refer to the following website for more information:-

http://www.hkfsd.gov.hk/home/eng/source/circular/2007_01.pdf

Please feel free to call Mr. WU Wai-hung, Samuel at 2733 7827 or Mr. LI Kai-chung at 2733 7557 for any other questions.

Yours faithfully,


(CHAN Ka-chi)
for Director of Fire Services

CKC/wwhs